

2018 YEARLY PM TV MAINTENANCE

SUBDIVISION	ADDRESS	DISTANCE TELEVISED	MH#	TO	MH#	Type	Date of TV	Recommended Resolution	Date Resolved
Powers Place	10122 Powers Drive	343	01-18		01-17	Main under home	12/4/2018	Line Relocation	
Powers Place	10122 Powers Drive	170	01-19		01-18	Main under home	12/4/2018	Line Relocation	
Town	106 Lamey	232	05-17		05-18	Whole line has offset joints	11/26/2018	Main Line Replacement (3 tap repairs bid in 2012)	
Town	517 Water St	207	09-02		05-31	Offset & ductile	11/21/2018	Future repair (193' from MH 09-02 where it changes to ductile)	
Town	321 Jennings (complaint from Carol Smith Interiors)	195	09-16		09-15	Minor crack in main at 86'	12/7/2018	None given	
Town	409 Jefferson	310	09-47		09-30	Whole line has offset joints & roots	12/10/2018	Replace line	
Town	425 Cypress	234	09-111		09-101	Main under home	11/21/2018	Line Relocation	
Town	Adams St	346	09-122		09-123	Offsets & Sags	11/28/2018	Main Line Replacement	
Town	223 Hillcrest	394	09-135		09-123	10 problems found, clay line	12/3/2018	Line Replacement	
Jefferson Park	Corner of Jefferson Ct & Jefferson Park	196	10-51		10-50	Aerial sewer	12/4/2018	None given	
Town	919 Jefferson ST	226	10-67		10-68	Offsets & cracks in main (6 repairs listed on on the Future Repair List)	12/4/2018	Added from Jefferson St Project May, 2012	
Town	905 Jefferson ST	195	10-239		10-67	Every joint offset	12/4/2018	Added from Jefferson St Project May, 2012	
Town	919 Jefferson ST	393	10-66		10-239 New MH	Offsets & cracks in main (4 repairs listed on on the Future Repair List)	12/4/2018	Added from Jefferson St Project May, 2012	
Town	810 Jefferson St	391	10-66		10-65	Offsets & cracks in main (2 repairs listed on on the Future Repair List)	12/5/2018	Added from Jefferson St Project May, 2012	
Town	700 Jefferson St	396	10-65		10-64	Offsets & roots in main (2 repairs listed on on the Future Repair List)	12/5/2018	Added from Jefferson St Project May, 2012	
GSV	Sycamore	151	11-202		11-201	Main under pool	12/7/2018	Possible CEI project	
GSV	8288 lincoln	332	11-235		11-236	from 150' to 200' cracked pipe next to home	12/3/2018		
Town	6466 Belle Rive Dr	367	13-02		13-01	Hole in main	11/29/2018	Also on Prev Maint/Ran backwards since upstream MH in landscaping	
Lakevale Estates	6244 Pfaffin Lake Blvd	0	13-78		13-78	Monitor manhole/overflow 10/24/12 due to root clog		Monitor only at this time	
Old Stonehouse	7133 Stonebridge Dr	0	13-131		13-131	Monitor manhole/overflow 11/1/12 due to root clog		Manhole needs replaced	
Broadview	7599 Broadview	380	15-188		15-192	Main under home DO NOT ROOT CUT WITHOUT DOING TV FIRST	12/7/2018	Line Relocation	
Buslers	Walgreens	139	15-223		15-25	Roots	11/29/2018	Point rep & Rootx	
Total Line Rehab:		5,217							